

DETAILS OF CONTRACTS AWARDED ON SINGLE TENDER (OEM/OES/PAC/SS) BASIS ---- HQ

PERIOD :FEBRUARY, 2022.							
Sl. No.	Name of the Project	Details of Work	Name of the Awardee	Type or Nature of Single Tenders (OEM / OES/PAC/SS)	Reason / Justification for awarding the work on Single Tender Basis	Work Order No. and Date	Value of Contract Awarded
1	DVC, Kolkata	Re-conductoring of 220KV D/C Parulia (DVC) Parulia (POWERGRID) Tie-Line with HTLS conductor & Up-gradation of associated Bay-equipments	M/s PGCIL	Single(PSU)	<p>The work for re-conductoring of 220KV D/C Parulia (DVC) –Parulia(POWERGRID) tie-line with HTLS conductor & up-gradation of associated bay-equipments is required for strengthening of the said line as advised in the 4th- ERPCTP meeting minutes of CEA (dated 23/07/2021) with sl. No: 6.0.</p> <p>Reconductoring of old 220kv transmission lines with HTLS conductors by simply changing the conductor & its compatible hardware accessories and minor changes required in the tower structure cross arms is a new technology. DVC is yet to adopt the same for 220kv lines with this high amperage capacity HTLS conductor. However, PGCIL being a CTU having a Pan India Network does have the technology which was verbally confirmed.</p> <p>Considering the importance of 220kv D/C Parulia DVC - Parulia PGCIL tie and requirement expressed at ERPC TP (CEA), re-conductoring work is essential for the said line. Shutdown of single-circuit line can be availed at this juncture.</p> <p>In view of above, it was proposed to engage PGCIL on deposit work basis to carry out the complete work as elaborated in the scope of work.</p>	Work Order No. DVC/Contract/Head Quarter/SPE/CMM /Works and Service/00027 dated 01/02/2022	Total financial involvement is Rs. 7.84 Crore excluding GST on consultancy fee (@18%) only.